

CUSTOMER:		SERIAL No:	ORDER No:	All dimensions in mm	
			<p>MAIN EQUIPMENT:</p> <p>WMBC175 2x EVAPORATOR FANS</p> <p>WMBC220 2x EVAPORATOR FANS</p> <p>WMBC350 3x EVAPORATOR FANS</p>		
<p>ROLL IN BLAST CHILLER</p> <p>CONTROLS:</p> <p>WEB CONTROLLER (C/W PRINTER)</p>			<p>EVAPORATOR COIL c/w EXP VALVE</p> <p>GAS R404a</p> <p>ELECTRIC DEFROST</p>		
<p>AMPS:</p> <p>WMBC 175/220/350: 16Amps</p>			<p>DRAIN FACILITY REQUIRED</p>		
<p>SUPPLY:</p> <p>208-230v / 60hz / 3ph</p>			<p>STORAGE POD EQUIPMENT:</p> <p>1 FAN POD (50mm)</p> <p>EVAPORATOR COIL c/w EXP VALVE</p> <p>GAS 134a</p> <p>ELECTRIC DEFROST</p> <p>ELEC VAP TRAY</p> <p>COND UNIT 0.5 HP</p>		
<p>FINISH:</p> <p>INT 441 S/S</p> <p>WHITE PVC</p> <p>EXT 430 S/S</p> <p>441 S/S</p> <p>WHITE PVC</p>			<p>CONDENSING UNIT:</p> <p>BTU REQUIREMENTS AT 32°C / 90°F AMBIENT</p> <p>MODEL BTU's / HOUR</p> <p>WMBC175 29340 " 5°C EVAP</p> <p>WMBC220 34250 " 5°C EVAP</p> <p>WMBC350 59080 " 5°C EVAP</p>		
<p>CAPACITY:</p> <p>WMBC175 175lbs / 90mins</p> <p>WMBC220 220lbs / 90mins</p> <p>WMBC350 350lbs / 90mins</p>			<p>DRAIN FACILITY REQUIRED</p>		
<p>FLOORLESS</p>			<p>920 COV CNR JAMB</p> <p>700 C/O</p> <p>SPECIFY HANG</p>		
<p>550 CNR F/F</p> <p>920 COV CNR JAMB</p> <p>700 C/O R/H</p>			<p>550 CNR F/F</p> <p>920 COV CNR JAMB</p> <p>700 C/O R/H</p>		
<p>Williams Refrigeration</p> <p>Bryggen Road</p> <p>North Lynn Industrial Estate</p> <p>Kings Lynn, Norfolk,</p> <p>PE30 2HZ</p>		<p>This drawing and all copies produced are the property of Williams Refrigeration and must not be copied or distributed by any third party without obtaining authorisation.</p>		<p>DRAWING TITLE:</p> <p>WMBC 175-220-350 PT c/w POD</p> <p>ROLL-IN BLAST CHILLER (BEV-AIR SPEC)</p>	
<p>DRAWN BY:</p> <p>JJA</p>		<p>DATE:</p> <p>14/02/14</p>		<p>SCALE:</p> <p>1:26</p>	
<p>CHECKED BY:</p>		<p>DATE:</p>		<p>DRAWING NUMBER:</p> <p>E:/Spec-Drg/Bev-Air WMBC/WMBC 175-220-350 PT Pod</p>	
<p>ISSUE:</p> <p>001</p>					